

X

इंटरनेट

Disclosure to Promote the Right To Information

Whereas the Parliament of India has set out to provide a practical regime of right to information for citizens to secure access to information under the control of public authorities, in order to promote transparency and accountability in the working of every public authority, and whereas the attached publication of the Bureau of Indian Standards is of particular interest to the public, particularly disadvantaged communities and those engaged in the pursuit of education and knowledge, the attached public safety standard is made available to promote the timely dissemination of this information in an accurate manner to the public.

"जानने का अधिकार, जीने का अधिकार" Mazdoor Kisan Shakti Sangathan "The Right to Information, The Right to Live"

 $\star \star \star \star \star \star \star \star$

"पुराने को छोड नये के तरफ" Jawaharlal Nehru "Step Out From the Old to the New"

मानक

IS 2685 (1971): Code of practice for selection, installation and maintenance of sluice valves [CED 3: Sanitary Appliances and Water Fittings]



611111111

Made Available By Public, Resource, Org

 $\star \star \star \star \star \star \star$



RIGHT TO INFORMATION "ज्ञान एक ऐसा खजाना है जो कभी चुराया नहीं जा सकता Bhartrhari-Nītiśatakam "Knowledge is such a treasure which cannot be stolen"

BLANK PAGE



PROTECTED BY COPYRIGHT

Indian Standard CODE OF PRACTICE FOR SELECTION, INSTALLATION AND MAINTENANCE OF SLUICE VALVES

(First Revision)

Sixth Reprint SEPTEMBER 1993

UDC 621.646.5.005

© Copyright 1971

BUREAU OF INDIAN STANDARDS MANAK BHAVAN, 9 BAHADUR SHAH ZAFAR MARG NEW DELHI 110002

Indian Standard

CODE OF PRACTICE FOR SELECTION, INSTALLATION AND MAINTENANCE OF SLUICE VALVES

(First Revision)

Chairman	Representing
THE DIRECTOR	Central Public Health Engineering Research Institute (CSIR), Nagpur
Members	
Adviser	Ministry of Health, Family Planning & Works, Housing & Urban Development
SHRI H. R. BADYAL SHRI K. D. BISWAS (Alternate)	The Indian Iron and Steel Co Ltd, Calcutta
SHRI V. D. CHADHA	Ministry of Railways
CHIEF ENGINEER	Central Public Works Department
SUPERINTENDING ENGINEER (A	liernate)
CHIEF ENGINEER	Local Self Government Engineering Department, Government of Uttar Pradesh
SUPERINTENDING ENGINEER (A	liernate)
CHIEF ENGINEER (WATER) DRAINAGE ENGINEER (Allernald	Municipal Corporation of Delhi
CITY ENGINEER SHRI Y. H. KAMAT (Alternale)	Bombay Municipal Corporation
SHRI H. N. DALLAS	The Indian Institute of Architects, Bombay
LALA G. C. DAS	National Test House, Calcutta
SHRI M. K. GANPULE	All India Pottery Manufacturers' Association, Calcutta
SHRI R. M. MEHRA (Alternate)
SHRI K. C. JERATH	Engineer-in-Chief's Branch, Army Headquarters
SHRI J. THOMES (Alternate)	
SHRI M. T. KANSE	Directorate General of Supplies & Disposals
SHRI G. S. SUBBARAMAN (Aller	nate)
Shri R. V. Lele	(CSIR), Calcutta
Shri G. A. Luhar	Indian Non-ferrous Metals Manufacturers Associa- tion, Calcutta
SHRI R. N. MALLICK	Directorate General of Technical Development
SHRI N. R. SRINIVASAN (Alteri	nate)
SHRI R. M. MEHRA	Bombay Potteries & Tiles Ltd, Bombay
	(Continued on page 2)

BUREAU OF INDIAN STANDARDS MANAK BHAVAN, 9 BAHADUR SHAH ZAFAR MARG NEW DELHI 110002

Conner

(Continued from page 1) Members Representing SHRI V. P. NARAYANAN NAYAR Public Health Engineering Department, Government of Kerala SHRI R. PARIKSHIT Indian Section of Plastic Institute, New Delhi SHRI A. H. PATEL Ahmedabad Municipal Corporation DR A. V. R. RAO National Buildings Organization (Ministry of Works, Housing & Urban Development) SHRI G. T. BHIDE (Alternate) REPRESENTATIVE Central Building Research Institute (CSIR), Roorkee Hindustan Shipyard Ltd, Visakhapatnam Institution of Engineers (India), Calcutta REPRESENTATIVE *SHRI B. B. RAU SHRI R. K. SOMANY Hindustan Sanitaryware Industries Ltd, Bahadurgarh SHRI V. S. BHATT (Alternate) E. I. D. Parry Ltd, Madras SHRI B. ULLAL SHRI T. S. CHINTAMANI (Alternate) SHRI D. AJITHA SIMHA, Director General, ISI (Ex-officio Member) Director (Civ Engg)

Secretary

SHRI C. R. RAMA RAO Deputy Director (Civ Engg), ISI

Water Works Fittings Subcommittee, BDC 3:5

Gomeener	
Shri Y. H. Kamat	Bombay Municipal Corporation
Members	
Shri J. R. Aggarwal Shri Yash Raj Aggarwal (<i>Ali</i>	Govardhan Das P. A, Jullundur City ternate)
SHRI H. R. BADYAL SHRI K. D. BISWAS (Alternate)	The Indian Iron & Steel Co Ltd, Calcutta
SHRI T. C. BASU	Burn & Co Ltd, Calcutta
Shri K. K. Bhattacharyya Shri A. K. Bhattacharyya (A	Indian Valve Co Ltd, Calcutta Ilternate)
SHRI V. D. CHADHA	Ministry of Railways
CHIEF ENGINEER	Local Self Government Engineering Department Government of Uttar Pradesh
SUPERINTENDING ENGINEER (All	ernate)
CHIEF ENGINEER (WATER) DEPUTY CHIEF ENGINEER (WAT	Delhi Municipal Corporation ER) (Alternate)
Shri J. D. Daroga	Italab Engineering Pvt Ltd, Bombay
Shri M. K. Das Gupta	National Physical Laboratory (CSIR), New Delhi
Shri M. L. Mutaliok Desai Shri V. P. Havaldar (<i>Alietnai</i>	Kirloskar Brothers Ltd, Kirloskarwadi

(Continued on page 7)

^{*}He is also alternate to the adviser, Ministry of Health, Family Planning & Works, Housing & Urban Development.

Indian Standard

CODE OF PRACTICE FOR SELECTION, INSTALLATION AND MAINTENANCE OF SLUICE VALVES

(First Revision)

0. FOREWORD

0.1 This Indian Standard (First Revision) was adopted by the Indian Standards Institution on 30 July 1971, after the draft finalized by the Sanitary Appliances and Water Fittings Sectional Committee had been approved by the Civil Engineering Division Council.

0.2 This standard was first published in 1964. The Sectional Committee has revised the standard after reviewing it in the light of experience gained in the usage of the same and has incorporated the necessary modifications to facilitate the use of valves conforming to IS: 780-1969*.

0.3 For the purpose of deciding whether a particular requirement of this standard is complied with, the final value, observed or calculated, expressing the result of a test or analysis, shall be rounded off in accordance with IS: 2-1960[†]. The number of significant places retained in the rounded off value should be the same as that of the specified value in this standard.

1. SCOPE

1.1 This code covers the selection, installation and maintenance of sluice valves conforming to IS: 780-1969*.

2. SELECTION

2.1 The aspects governing the selection of sluice valves are listed below:

- a) Nominal bore of pipe.
- b) Nature of Pipe whether it is made of cast iron, cast steel, asbestos-cement or steel coated with concrete.
- c) Situation --- whether distribution or rising main.

†Rules for rounding off numerical values (revised).

^{*}Specification for sluice valves for water-works purposes (50 to 300 mm size) (fourth revision).

IS: 2685 - 1971

- d) Location whether underground or above.
- e) Nature of location of the valve which would depend upon the following factors:
 - 1) Whether centre line of spindle is vertical or horizontal, and
 - 2) Whether inside or in a terminal position in a pipe line.
- f) Nature of end connections, namely, flanged, socketed or plained ended.
- g) Quality of water:
 - 1) Whether raw unfiltered or filtered;
 - 2) Acidic or alkaline, if possible *pH* value (hydrogen-ion concentration); and
 - 3) Temperature.
- h) Pressure of water, both working and unbalanced, and the static head at the centre of the valve.

NOTE — Unbalanced pressure is the difference between the pressures on the two sides of the door with the valve shut. This determines the resultant unbalanced thrust against which the valve has to be operated.

- j) For headstock operation only:
 - 1) Distance, between the centre line of waterway and the base of headstock, that is level of operating platform;
 - 2) Distance between the centre line of extension spindle and the face of wall or masonry; and
 - 3) Headroom available on the operating platform.

3. INSTALLATION

3.1 Sluice valves shall normally be installed with spindle vertical on horizontal pipes except on vertical pipes where spindle shall be horizontal. On slopes, the sluice valves may preferably be kept vertical if slope is nominal and gradient can be adjusted with the help of connecting pipes on either sides.

3.1.1 It shall be ensured while fixing sluice valves in pipe lines below ground level that a clear space of about 200 mm is available between the top of the sluice valve spindle and surface box, so that valve cap may be easily provided when surface box is kept in flush with road level.

3.2 It is most important to ensure that:

a) all grit and foreign matters are removed from the inside of the valves before placing in pipes, and

b) all the four faces are thoroughly cleaned and coated with a thin layer of mineral grease.

3.3 It is important to check tightening of gland with a pair of inside calipers. Clearance between the top of the stuffing box and the underside of the gland should be uniform on all the sides.

3.4 Gland should not be tightened too hard. The pressure applied should be just enough to stanch leakage.

3.5 Hemp packing should be adequately soaked in grease and should not be allowed to remain dry.

3.6 The valves should be tightly closed when being installed, as this keeps the valve rigid and prevents any foreign matter from getting in between the working parts of the valve.

3.7 While installing flanged valves, each flange bolt should be tightened a little at a time, taking care to tighten diametrically opposite bolts alternately. The practice of fully tightening the bolts one after the other is highly undesirable.

3.8 After installation of the valve, the valve and the pipe line should be flushed with water to remove any foreign matter that may be present in them.

3.9 If any leak is detected at the valve seats, applying extra torque on the valve spindle to set right the valve is not good practice. The valve seats should be examined and, if necessary, repaired by scraping or replacing where necessary.

3.10 Valves in exposed positions should be protected in cold weather where there is a likelihood of their becoming frozen and bursting.

3.11 Surface boxes conforming to IS: 3950-1966* should be provided to cover the valve chamber for the safety and easy indentification of the valves.

3.12 The direction of opening and closing should be clearly indicated.

3.13 Suitable identification plate should be provided as near to the actual location of valves as possible.

3.14 Care should be taken to ensure that the joining material sits squarely between the flanges of the valves and pipe lines or tails without obstructing the waterway. It is equally important to ensure that there are no kinks in the jointing material as might allow leakage in service.

^{*}Specification for surface boxes for sluice valves.

IS: 2685 - 1971

4. MAINTENANCE

4.1 A value normally kept open or shut in a pipe should be operated once every three months to full travel of gate and any jamming that may have developed due to its remaining unused is to be freed.

4.2 It should be ensured that packings inside stuffing box are in good trim and impregnated with grease. It may be necessary to change the packing as often as necessary to ensure these requirements.

4.3 For T-key operation the end of the key should have good fit on the square taper at the top of spindle. It is dangerous to operate valves by oversize keys fitted direct to the spindle as this practice may result in rounded square top and the key may eventually slip.

4.4 Partial opening of valves frequently in a pipe is dangerous particularly against high unbalanced pressures. Where frequent partial opening of a valve is necessary against high unbalanced pressures a duplicate valve may be provided on the upstream side of the operating valve which should be kept fully open all the time. This will enable isolation of the pipe section for repairing the operative valve when it becomes defective.

4.4.1 Where a value has been fully opened, the back-lash should be taken out and the value slightly eased so that it will not stick.

4.5 The valve should be regularly inspected internally and externally, preferably, at intervals of not more than a year, the frequency of inspections depending upon the service conditions and the frequency of valve operations. The stuffing box packing should be adjusted or replaced soon after leakage past the spindle is detected.

(Continued from page 2)

Members

SHRI S. K. GAMBHIR SHRI M. C. AICH (Alternate) Shri A. Ghosh SHRI A. OHOSH SHRI M. M. MUNSHI SHRI S. J. REGE (Alternate) SHRI V. P. NARAYANAN NAYAR

SHRI RAMESHCHANDRA H. THAKKAR Geeta Iron & Brass Works, Baroda SHRI NAND KUMAR H. THAKKAR (Alternate) REPRESENTATIVE

SHRI V. RAMAN (Alternate) SHRI A. K. RAY

Representing

Directorate General of Supplies & Disposals

National Test House, Calcutta Garlick & Co Pvt Ltd, Bombay

Public Health Engineering Department, Government of Kerala

Central Public Health Engineering Research Institute (CSIR), Nagpur

Annapurna Metal Works, Calcutta

BUREAU OF INDIAN STANDARDS

Headquarters:				
Manak Bhavan, 9 Bahadur Shah Zafar Marg, N	EW DELHI 110	002		
Telephones: 331 01 31, 331 13 75 Telephones: 331 01 31, 331 13 75 (elegrams: Mana Common to all	ksai Offi	nst ce	:ha s)
Regional Offices:	7	elep	ho	ne
Central : Manak Bhavan, 9 Bahadur Shah Zafar NEW DELHI 110002	Marg, (33 }33	31 0 31 1	1 : 3 [:]	31 75
*Eastern : 1/14 C. I. T. Scheme VII M, V. I. P. Maniktola, CALCUTTA 700054	Road,	36 2	4	99
Nortnern : SCO 445-446, Sector 35-C, CHANDIGARH 160036		21	8	43 41
Southern : C. I. T. Campus, MADRAS 600113	{	412 412 412	.4 25 9	42 19 16
†Western : Manakalaya, E9 MIDC, Marol, Andh BOMBAY 400093	eri (East), 6 3	32 9	2	95
Branch Offices:				
'Pushpak', Nurmohamed Shaikh Marg, Khanpur, AHMADABAD 380001	\$	26 26	34 34	48 49
‡Peenya Industrial Area 1st Stage, Bangalore T BANGALORE 560058	umkur Road	384 384	9 ! 9 !	55 56
Gangotri Complex, 5th Floor, Bhadbhada Road, BHOPAL 462003	T. T. Nagar,	6 6	7 '	16
Plot No. 82/83, Lewis Road, BHUBANESHWAR 53/5, Ward No. 29, R.G. Barua Road, 5th Byela GUWAHATI 781003	751002 ne,	53 33	6 2 1 7	27 77
5-8-56C L, N. Gupta Marg (Nampally Station R HYDERABAD 500001	oad), 2	23 1	0 E	33
R14 Yudhister Marg, C Scheme, JAIPUR 30200	5 {	63 69	47 83	71 32
117/418 B Sarvodaya Nagar, KANPUR 208005	{2	161	57 20	16
Patliputra Industrial Estate, PATNA 800013 T.C. No. 14/1421, University P.O., Palayam	(2	62	30)5)7
TRIVANDRUM 695035	1 1	6 2'	1	7
Inspection Offices (With Sale Point):	•			
Pushpanjali, First Floor, 205-A West High Court Shankar Nagar Square, NAGPUR 440010	Road,	2 51	17	1
Institution of Engineers (India) Building, 1332 S PUNE 411005	ihivaji Nagar, I	5 24	3	5
*Sales Office in Calcutta is at 5 Chowringhee Approa Street, Calcutta 700072	ch, P. O. Princep	276	8 0	00
†Sales Office in Bombay is at Novelty Chamber Bombay 400007	s, Grant Road,	8 9 6	52	28

[‡]Sales Office in Bangalore is at Unity Building, Narasimharaja Square, 22 36 71 Bangalore 560002

AMENDMENT NO. 1 MARCH 1990 TO IS: 2685 - 1971 CODE OF PRACTICE FOR SELECTION, INSTALLATION AND MAINTENANCE OF SLUICE VALVES

(First Revision)

(Page 3, clause 0.2, last line) — Substitute 'IS : 780-1984*' for 'IS : 780-1969*'.

(Page 3, clause 1.1, last line) — Substitute 'IS : 780-1984*' for 'IS : 780-1969*'.

(Page 3, foot-note, first line) — Substitute '(sixth revision)' for '(fourth revision)'.

(Page 5, clause 3.11, first line) — Substitute 'IS : 3950 - 1979*' for 'IS : 3950-1966*'.

(Page 5, foot-note) — Insert '(first revision)' in the end.

(CED 3)

Reprography Unit, BIS, New Delhi, India