

X

इंटरनेट

### Disclosure to Promote the Right To Information

Whereas the Parliament of India has set out to provide a practical regime of right to information for citizens to secure access to information under the control of public authorities, in order to promote transparency and accountability in the working of every public authority, and whereas the attached publication of the Bureau of Indian Standards is of particular interest to the public, particularly disadvantaged communities and those engaged in the pursuit of education and knowledge, the attached public safety standard is made available to promote the timely dissemination of this information in an accurate manner to the public.

"जानने का अधिकार, जीने का अधिकार" Mazdoor Kisan Shakti Sangathan "The Right to Information, The Right to Live"

"पुराने को छोड नये के तरफ" Jawaharlal Nehru "Step Out From the Old to the New"

मानक

IS 942 (1982, Reaffirmed 2000): Functional Requirements for 275-1/min Portable Pump Set for Fire Fighting (Second Revision). UDC 614.846.1 : 621.65-182.4



611111111

Made Available By Public.Resource.Org



"ज्ञान से एक नये भारत का निर्माण″ Satyanarayan Gangaram Pitroda "Invent a New India Using Knowledge"

"ज्ञान एक ऐसा खजाना है जो कभी चुराया नहीं जा सकता Bhartrhari-Nītiśatakam "Knowledge is such a treasure which cannot be stolen"





# (Reaffirmed 2000) Indian Standard FUNCTIONAL REQUIREMENTS FOR 275 L'MIN PORTABLE PUMP SET FOR FIRE FIGHTING (Second Revision)

11DC 614/846/1 621/65-182/4



Copyright 1982

INDIAN STANDARDS INSTITUTION MANAK EHAVAN, 4 BAHADUR SHAH ZAFAR MARG NEW DELHE HORD

15 - 942 - 1982

#### IS:942-1982

## Indian Standard

### FUNCTIONAL REQUIREMENTS FOR 275 1/MIN PORTABLE PUMP SET FOR FIRE FIGHTING

## (Second Revision)

Fire Fighting Sectional Committee, BDC 22

Chairman

Representing

SHRI G. B. MENON

Ministry of Home Affairs

Members

SHRI MAHESH C. AGARWAL Brijbasi Udyog, Mathura SHRI P. S. BANERJEE ( Alternate ) Steel Authority of India Ltd (Bokaro Steel Plant), SHRI S. R. BANSAL Bokaro Tariff Advisory Committee, Bombay SHRI A. CHATTERJEE SHRI F. B. SANJANA ( Alternate ) DEPUTY INSPECTOR GENERAL Ministry of Railways (RPSE) ASSISTANT SECURITY OFFICER (FIRE) (NORTHERN RAIL-WAY) (Alternate) Ministry of Defence (DGI) SHRI V. P. DEWAN LT COL V. R. BANAHATI ( Alternate ) Home Department (Fire Service), Government of SHRI N. DEVASAHAYAM Tamil Nadu, Madras SHRI V. JAYAPERUMAL ( Alternate ) SHRI R. R. DHOBLEY Bhabha Atomic Research Centre, Trombay, Bombay Home (Police) Department, Government of Andhra **DIRECTOR, FIRE SERVICES** Pradesh, Hyderabad **DEPUTY DIRECTOR (FIRE** SERVICES ) ( Alternate ) Directorate General of Supplies and Disposals, SHRI G. N. GIDWANI New Delhi SHRI D. N. PANDIT ( Alternate ) SHRI GOPAL KRISHAN

Central Building Research Institute (CSIR), Roorkee

(Continued on page 2)

#### © Copyright 1982

#### INDIAN STANDARDS INSTITUTION

This publication is protected under the *Indian Copyright Act* (XIV of 1957) and reproduction in whole or in part by any means except with written permission of the publisher shall be deemed to be an infringement of copyright under the said Act.

#### IS:942-1982

(Continued from page 1)

Members Representing SHRI K. K. DAS GUPTA West Bengal Fire Service, Calcutta SHRI J. S. JAMSHEDJI Steelage Industries Ltd (Minimax Division), Bombay SHRI C. GHANARAJ ( Alternate ) JUNIOR MANAGER (FIRE) Heavy Engineering Corporation Ltd, Ranchi SHRI S. N. KUNDU Fire Safety Appliances Co, Calcutta SHRI S. PAUL ( Alternate ) Avon Services (P&A) Pvt Ltd, Bombay MANAGING DIRECTOR TECHNICAL EXECUTIVE ( Alternate ) SHRI L. S. D. MEHERVANJEE Municipal Corporation of Greater Bombay (Bombay Fire Brigade), Bombay SHRI V. B. NIKAM ( Alternate ) SHRI B. R. MEHTA Institution of Fire Engineers (India), New Delhi SHRI A. N. AHLUWALIA ( Alternate ) Steel Authority of India (Rourkela Steel Plant), SHRI M. MUKHERJI Rourkela SHRI C. D. SHARMA ( Alternate ) Central Industrial Security Force (Ministry of SHRI P. N. PANCHAL Home Affairs) COL V. V. K. RAO Ministry of Defence (R & D) SHRI MOHENDRA PRASAD ( Alternate ) SHRI K. K. SAWHNEY Air Foam Industries Pvt Ltd, New Delhi SHRI R. MEHTA ( Alternate ) SHRI P. L. SEBASTIN Oil & Natural Gas Commission, Dehra Dun SHRI V. V. KIMMATKAR ( Alternate ) SHRI P. H. SETHNA Kooverji Devshi & Co Pvt Ltd, Bombay SHRI N. T. PANJWANI ( Alternate ) SHRI CHANDRAKANT M. SHAH Zenith Fire Services, Bombay SHRI M. H. SHAH ( Alternate ) Newage Industries, Surendranagar (Gujarat) SHRI J. V. SHAH SHRI B. J. SHAH ( Alternate ) Municipal Corporation of Delhi (Delhi Fire SHRI S. S. L. SHARMA Services ), Delhi Synthetics & Chemicals Ltd, Bareilly SHRI D. K. SIRKAR SHRI TARIT SUR Sur Enamel & Stamping Works Pvt Ltd, Calcutta SHRIS. SUR (Alternate) Directorate General of Technical Development, SHRI SUSHIL KUMAR New Delhi Directorate General of Civil Aviation, New Delhi SHRI S. VENKASWAMY SHRI B. V. WAGLE Urban Development and Public Health Department, Government of Maharashtra, Bombay SHRI V. H. MADKAIKAR ( Alternate ) Director General, ISI ( Ex-officio Member ) SHRI G. RAMAN, Director ( Civ Engg )

#### Secretary

#### SHRI K. M. MATHUR Deputy Director (Civ Engg), ISI

(Continued on page 7)

## Indian Standard

### FUNCTIONAL REQUIREMENTS FOR 275 1/MIN PORTABLE PUMP SET FOR FIRE FIGHTING

## (Second Revision)

### $\mathbf{0}.\quad \mathbf{FOREWORD}$

0.1 This Indian Standard (Second Revision) was adopted by the Indian Standards Institution on 15 April 1982, after the draft finalized by the Fire Fighting Sectional Committee had been approved by the Civil Engineering Division Council.

**0.2** The portable pump set is one of the essential equipment for fire fighting. However, the capacity of this pump being limited, it cannot be relied upon for fighting large fires, but it has advantages of being lightweight and portable, which enables it to be carried almost anywhere. This type of pump is very suitable for small factories, railway/dock yards, areas where there are narrow lanes, rural areas and towns where water is scarce.

**0.2.1** This standard was first published in 1958 and revised in 1968. The second revision has been prepared to provide for use for diesel type of engines also.

0.3 For the purpose of deciding whether a particular requirement of this standard is complied with, the final value, observed or calculated, expressing the result of a test or analysis, shall be rounded off in accordance with IS:2-1960\*. The number of significant places retained in the rounded off value should be the same as that of the specified value in this standard.

### 1. SCOPE

1.1 This standard lays down the requirements regarding material and design of 275 l/min portable pump set for fire fighting.

<sup>\*</sup>Rules for rounding off numerical values ( revised ).

### 2. GENERAL REQUIREMENTS

2.1 The unit shall consist of the pump having an output of not less than 275 l/min at a pressure of  $4 \text{ kgf/cm}^2$ , fitted on a tubular steel frame and with anti-vibration coils/pads. The complete unit shall be of lightweight construction, so that it can be easily carried by two men.

### 3. MATERIAL

3.1 The pump comprising volute, body (casing) impeller and one delivery outlet shall be manufactured from light aluminium alloy conforming to IS:617-1975\*.

3.1.1 The mild steel tubes used for the fabrication of tubular frame shall conform to IS: 3601-1966<sup>†</sup>.

3.1.2 The spindle of the delivery valve shall be made of stainless steel conforming to 07CR18Ni9 Grade of IS: 6603-1972<sup>+</sup>.

3.2 All parts which form waterways, or come into contact with water, shall be of corrosion resisting material or treated in a suitable manner. All metal parts exposed to atmosphere shall be either corrosion resisting or treated in a suitable manner.

#### 4. DESIGN

4.1 The components of the unit shall comply with the following requirements.

**4.1.1** Engine

4.1.1.1 The engine shall be a single cylinder two-stroke or four-stroke petrol or diesel driven.

4.1.1.2 The engine shall be air-cooled.

4.1.1.3 A well designed hand starting device shall be provided to ensure reliable and quick starting engine.

**4.1.2** *Pump* 

4.1.2.1 The pump shall be of single stage centrifugal type, directly mounted on the extension of the crankshaft of the engine.

4.1.2.2 The pump casing shall be so designed as to afford easy access to the impeller and facilitate erection and inspection. The outer face of the pump casing shall carry the suction and delivery connections and their fittings and priming device.

<sup>\*</sup>Specification for aluminium and aluminium alloy ingots and castings for general engineering purposes (second revision).

<sup>†</sup>Specification for steel tubes of mechanical and general engineering purposes.

<sup>&</sup>lt;sup>‡</sup>Specification for stainless steel bars and flats.

4.1.2.3 The pump shall be fitted with mechanical gland of self adjusting type.

4.1.2.4 The pump shall be tested for the performance of its duties (see 4.1.2.5) at  $27^{\circ} \pm 2^{\circ}$ C and at pressure of 760 mm of mercury. The following allowances (deductions) shall be made:

- a) Output i) One percent of every 2.5°C rise in water temperature;
  - ii) 4 percent for every 300 mm elevation above mean sea level; and
  - iii) No allowance shall be made for humidity up to 75 percent. However, deductions at the rate of 1 percent of every 5 percent change in humidity shall be made when the humidity ranges from 75 to 95 percent.
- b) Lift i) 30 cm every 300 m elevation above mean sea level, and
  - ii) One percent for every 2.5°C rise in water temperature.

4.1.2.5 The pump shall be tested with suction stainer fitted continuously for 4 hours shall be with a lift of 3 m for the following duties:

Output l/min	Pressure kgf/cm <sup>2</sup>	
545	2.2	
365	3.5	
275	4.0	

4.1.2.6 The pump suction shall be fitted with 75 mm male round threads and female blank cap. The round threads shall confirm to Table 3 of IS: 902-1974\*.

**4.1.2.7** The delivery value shall be of screw down type and fitted with 63 mm female instantaneous coupling and blank cap. The delivery value shall confirm to IS: 4928-1968<sup>†</sup>.

**4.1.3** Primer — The primer shall be capable of lifting water at least through 7 m in not more than 45 seconds and shall be preferably fully automatic.

**4.1.4** Framework — It shall be of a cradle design made of tubular steel and provided with anti-vibration coils/pads.

<sup>\*</sup>Specification for suction hose couplings for fire fighting purposes (second revision). †Specification for quick closing clack-valve for centrifugal pump outlet.

### IS : 942 - 1982

4.1.4.1 The cradle shall be fitted with 4 folding handles of spring loaded type. The handles shall be capable of being used for tying the ropes for slingling the pump down in the well.

4.1.5 Suction Hose — The lengths of 75 mm suction hose shall be 4 of 2.5 m or 2 of 4.5 m conforming to IS: 2410-1963\*. The suction hose shall be fitted with 75 mm suction hose coupling conforming to IS: 902-1974<sup>†</sup>.

**4.1.6** Fuel Tank — The fuel tank shall have a capacity for 2 hours continuous running.

**4.1.7** The control panel shall include:

- a) Hand trottle,
- b) Pressure gauge calibrated from 0 to 10 kgf/cm<sup>2</sup>, and
- c) Compound gauge with pressure calibrated from 0 to 6 kgf/cm<sup>2</sup> in black and vacuum 0 to 75 cms of mercury in red.

4.2 Tools and Instruction Book — A tool kit comprising all essential tools required for normal maintenance, shall be provided with each pump along with a fully illustrated booklet and itemwise spare parts list.

4.3 Weight — The total weight of the unit with fuel shall not exceed 110 kgs.

### 5. WORKMANSHIP AND FINISH

5.1 All parts of the unit shall be of good workmanship.

5.2 The cradle shall be painted in Fire Red (see Shade No. 536 of IS: 5-1978<sup>‡</sup>). The paint shall conform to IS: 2932-1974§.

### 6. MARKINGS

**6.1** Each pump set shall be clearly and permanently marked with the following information:

- a) Manufacturer's name or trade-mark;
- b) Type of engine and pump;
- c) The output of the pump in l/min;
- d) Weight of the pump set;
- e) Year of manufacture; and
- f) Instructions for operation of the pump.

<sup>\*</sup>Specification for suction hose of rubber for fire services.

<sup>†</sup>Specification for suction hose couplings for fire fighting (second revision).

<sup>\$\$</sup> Specification for colours for ready mixed paints and enamels ( third revision ).

<sup>§</sup>Specification for enamel, synthetic, exterior (a undercoating, (b) finishing (first revision).

(Continued from page 2)

### Fire Fighting Units Subcommittee, BDC 22:3

Convener

Representing

SHRI P. N. GHOSH

Institution of Fire Engineers (India), New Delhi

Members

Shri S. A. Chattopadhyay ( .	Alternate to		
Shri P. N. Ghosh )			
Shri K. K. Das Gupta	West Bengal Fire Services, Calcutta		
Shri V. P. Dewan	Ministry of Defence (DGI)		
LT COL V. R. BANAHATI ( Alte	rnate)		
Shri G. N. Gidwani	Directorate General of Supplies and Disposals, New Delhi		
SHRI D. N. PANDIT ( Alternate	)		
Shri L. S. D. Mehervanjee	Municipal Corporation of Greater Bombay (Bombay Fire Brigade), Bombay		
SHRI V. B. NIKAM ( Alternate )			
Shri G. B. Menon	Ministry of Home Affairs		
COL S. A. MOHILE	Ministry of Defence (R & D)		
SHRI A. K. SURI ( Alternate )			
SHRI P. H. SETHNA	Kooverji Devshi & Co Pvt Ltd. Bombay		
SHRI N. T. PANJWANI ( Alterna	ite)		
Shri S. S. L. Sharma	Municipal Corporation of Delhi (Delhi Fire Services), Delhi		
Shri D. K. Sirkar	Synthetics & Chemicals Ltd, Bareilly		
Shri S. Venkaswamy	Directorate General of Civil Aviation, New Delhi		
SHRI B. V. WAGLE	Urban Development Public Health and Housing Department, Government of Maharashtra, Bombay		

SHRI V. H. MADKAIKAR ( Alternate )

### INTERNATIONAL SYSTEM OF UNITS (SI UNITS)

### **Base Units**

Quantity	Unit	Symbol	
Length	metre	m	
Mass	kilogram	kg	
Time	second	S	
Electric current	ampere	Α	
Thermodynamic temperature	kelvin	K	
Luminous intensity	candela	cd	
Amount of substance	mole	mol	
Supplementary Units			
Quantity	Unit	Symbol	
Plane angle	radian	rad	
Solid angle	steradian	sr	
Derived Units			
Quantity	Unit	Sy <b>m</b> bol	Definition
Force	newton	N	$1 N = 1 kg. m/s^{3}$
Energy	joule	J	1 $J=1$ N.m
Power	watt	W	1 W=1 J/s
Flux	weber	Wb	1  Wb = 1  V.s
Flux density	tesla	Τ	$1 T = 1 Wb/m^{2}$
Frequency	hertz	Hz	1 Hz=1 c/s $(s^{-1})$
Electric conductance	siemens	S	1 $S=1 A/V$
Electromotive force	volt	v	1 V=1 W/A
Pressure, stress	pascal	Pa	$1 Pa = 1 N/m^2$

•